

24501

ALERT*ALERT*ALERT*ALERT**Facilities Management Outage Notification***Please Post Centrally in Your Department***EMERGENCY****Fire System Fire Suppression Outage EXTENDED UNTIL 2025-Oct-10 15:00****BLDG: 0055 Garrett Hall****ALL FLOORS AFFECTED**

Impact to Building Occupants: No Fire Suppression
The Mist system has been shut off due to a low jockey bottle

| | |
|--|--|
| Scheduled Start Date and Time: | 2025-Jul-21 12:00 |
| Scheduled End Date and Time: | 2025-Jul-28 15:00 |
| Reason for Outage: | The Mist system has been shut off due to a low jockey bottle |
| Requested By: | Gaines Barnett (UVA FM Operations) |
| Outage Coordinator | Gaines Barnett 434-566-7275 |
| Customers with Whom the Outage was Coordinated: | Alex Harlow |
| Outage Approved By: | Randy Spencer (UVA FM Operations) |

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

ALERT*ALERT*ALERT*ALERT

Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists

<https://www.fm.virginia.edu/resources/outages/outagesubs.html>