

25799

ALERT*ALERT*ALERT*ALERT**Facilities Management Outage Notification*****Please Post Centrally in Your Department*****Fire System Fire Suppression Outage****BLDG: 0055 Garrett Hall****ALL FLOORS AFFECTED****Impact to Building Occupants: No Fire Suppression**

The Mist system has been shut off due to a low jockey bottle. This is an extension to the current outage. Outage was extended due to part delivery time. Part timeline has been updated, awaiting contractor for installation

Scheduled Start Date and Time:	2025-Nov-26 15:19
Scheduled End Date and Time:	2025-Dec-18 15:00
Reason for Outage:	The Mist system has been shut off due to a low jockey bottle, This has been an ongoing outage that has been coordinated. Still awaiting critical parts that have been on order.
Requested By:	Jacob Campbell (UVA FM-Operations)
Outage Coordinator	Gaines Barnett 434-566-7275
Customers with Whom the Outage was Coordinated:	Dakota Workman
Outage Approved By:	Randy Spencer (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

ALERT*ALERT*ALERT*ALERT

Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists

<https://www.fm.virginia.edu/resources/outages/outagesubs.html>