

25400

ALERT*ALERT*ALERT*ALERT**Facilities Management Outage Notification***Please Post Centrally in Your Department***EMERGENCY****Water Heating Hot Water Outage****BLDG: 0056 Varsity Hall****ALL FLOORS AFFECTED****Impact to Building Occupants: Building will be cooler and more humid**

Scheduled Start Date and Time:	2025-Sep-17 06:00
Scheduled End Date and Time:	2025-Sep-17 15:30
Reason for Outage:	Leaking 2" MTHW service within tunnel entering Varsity Hall at the Main Distribution connection.
Requested By:	Corey Jones (UVA FM E&U)
Outage Coordinator	Donald (Randy) Spencer 434-531-6993
Customers with Whom the Outage was Coordinated:	Randy Spencer Central Grounds Zone Maintenance Manager
Outage Approved By:	Randy Spencer (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

ALERT*ALERT*ALERT*ALERT**Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists**<https://www.fm.virginia.edu/resources/outages/outagesubs.html>