

23503

ALERT*ALERT*ALERT*ALERT**Facilities Management Outage Notification*****Please Post Centrally in Your Department*****EMERGENCY****Fire System Sprinkler System Outage****BLDG: 0068 Clark Hall****Affected Floors / Rooms: attic in old Clark Hall Breezeway****Impact to Building Occupants: No Fire Suppression****The dry system that feeds the attic in old Clark Hall Breezeway is down the replacement is coming in this week**

Scheduled Start Date and Time:	2025-Apr-29 14:18
Scheduled End Date and Time:	2025-May-05 12:00
Reason for Outage:	The dry system that feeds the attic in old Clark Hall Breezeway is down the replacement is coming in this week
Requested By:	Gaines Barnett (UVA FM Operations)
Outage Coordinator	Gaines Barnett 434-566-7275
Customers with Whom the Outage was Coordinated:	Alex Harlow
Outage Approved By:	Randy Spencer (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

ALERT*ALERT*ALERT*ALERT**Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists**<https://www.fm.virginia.edu/resources/outages/outagesubs.html>