

20383

ALERT*ALERT*ALERT*ALERT**Facilities Management Outage Notification***Please Post Centrally in Your Department***EMERGENCY****Fire System Sprinkler System Outage****BLDG: 0094 Bryan Hall****Affected Floors / Rooms: Breezeway Only****Impact to Building Occupants: No Fire Suppression**

Scheduled Start Date and Time:	2024-Aug-16 14:43
Scheduled End Date and Time:	2024-Aug-23 15:00
Reason for Outage:	Contractors working on Drains in Bryan Hall saw cut through a sprinkler pipe. Piping cannot be repaired at this time until waterproofing membrane has been pulled up.
Requested By:	Forrest Johnson (UVA FM Fire and Life Safety)
Outage Coordinator	Donald (Randy) Spencer 434-531-6993
Customers with Whom the Outage was Coordinated:	Randy Spencer, Zone Manager, FM
Outage Approved By:	Randy Spencer (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

ALERT*ALERT*ALERT*ALERT**Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists**<https://www.fm.virginia.edu/resources/outages/outagesubs.html>