

11963

ALERT*ALERT*ALERT*ALERT

Facilities Management Outage Notification

Please Post Centrally in Your Department

EMERGENCY

Water Hot and Cold Outage

BLDG: 0136 WILSON HALL

ALL FLOORS AFFECTED

**Impact to Building Occupants: No Cold Water, No Hot Water, No Drinking Water, No Flushing or Shower water
Bathrooms will be closed and water-supplied fixtures will be out of service (sinks, toilets, urinals, and drinking fountains). The leak is in a mechanical room in the basement of Wilson Hall so no other spaces are at risk of water damage.**

Scheduled Start Date and Time:	2022-Mar-01 08:00
Scheduled End Date and Time:	2022-Mar-01 14:00
Reason for Outage:	Water pipe in basement of Wilson Hall has ruptured, and domestic water service was shut down to prevent damage to building and its systems. The leak is in a mechanical room, and no occupied spaces in the building are affected by possible water damage.
Requested By:	Jacob Campbell (UVA Facilities Management)
Outage Coordinator	Ryan Taylor 434-981-8874
Customers with Whom the Outage was Coordinated:	Brandon Edwards (243-8855) bne4kd@virginia.edu Anna Towns (243-8590) akt2m@virginia.edu Franklin Coffman (243-6710) fec4n@Virginia.EDU Lela Marshall (982-4711) llb8b@virginia.edu Martha Stuart (924-6313) mws4s@virginia.edu Sinisa Maricic (260-6367) sm6he@virginia.edu Preston Godfrey (243-8628) peg7e@virginia.edu
Outage Approved By:	Ryan Taylor (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator

- immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) **PRIOR TO THE START** and upon **COMPLETION** of all work

ALERT*ALERT*ALERT*ALERT

Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists

<https://www.fm.virginia.edu/resources/outagesubs.html>