

15703

*ALERT*ALERT*ALERT*

Facilities Management Outage Notification

Please Post Centrally in Your Department

EMERGENCY

Water Hot Outage

BLDG: 0421 Madison Hall

ALL FLOORS AFFECTED

Impact to Building Occupants: No Hot Water

Hot Water pump failed causing an emergency outage for hot water for

Madison hall. We are working to replace the pump as soon as possible and
we will send communication out when hot water has been restored.

Contact our team if you have any additional questions: Randy Spencer: DRS2Y@virginia.edu Jacob Campbell: JRC3ZZ@virginia.edu

Scheduled Start Date and Time:	2023-Aug-16 08:15
Scheduled End Date and Time:	2023-Aug-16 17:00
Reason for Outage:	Hot water pump failed and started leaking in mechanical room. Isolating it caused hot water to shut off for the building
Requested By:	Jacob Campbell (UVA Facilities Management)
Outage Coordinator	Donald Spencer 434-531-6993
Customers with Whom the Outage was Coordinated:	Justina Duncan (924-6775) jd2qr@virginia.edu,PR-Presidents Office Administration Brain Cullaty brc7q@virginia.edu, Executive Director for Operations, Office of the President
Outage Approved By:	Randy Spencer (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction

2. Those performing work associated with this outage <u>MUST</u> notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

*ALERT*ALERT*ALERT*

Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists

https://www.fm.virginia.edu/resources/outagesubs.html