

ALERT*ALERT*ALERT*ALERT
FIRE ALARM INSPECTION / TEST
PLEASE POST CENTRALLY IN YOUR DEPARTMENT

**FACILITIES MANAGEMENT WILL BE INSPECTING / TESTING THE FIRE
ALARM SYSTEM IN BLDG:**

1150 University Hospital

AFFECTED FLOORS: Fourth 2M

testing will only take place at 2MA and 4th floor of the hospital addition

Additional Information:

Fire Doors Will NOT Close	
AHUs Will Shut Down & Immediately Restart	
AFFECTED AHUs:	4th floor server room liebert units will shut down and restart immediately 2ma server room -AHU-RX-1 will shutdown and restart immediately.
Testing has been approved by Ron Clark and Fred Burford. generator will run for 2ma server room during testing.	

Details Of Testing:

Scheduled Dates:	2019-May-16 17:00 - 2019-May-16 22:00
Work Order Number:	2895188
POC For Testing:	Matthew Brown 434-566-7878
Approved By:	Richard Barbour

Additional Notes for Fire System Maintenance Personnel

Note 1: Ensure there is not any troubles on the fire panel when system is back in service

Note 2: Per State Fire Marshal - Fire watch must be provided when the fire alarm or sprinkler systems are out of service. HSPP Fire Marshal must be notified 24 hours prior to taking the system offline by email: aco9m@virginia.edu

Note 3: Submit fire watch log and documentation to Chuck Parker, Deputy Director, at conclusion of testing

Note 4: Contact HSPP Service Desk (4-8091) and Systems Control (2-4685) prior to starting and upon completion of all work

ALERT*ALERT*ALERT*ALERT

Please use the below link to unsubscribe from these notification, change, or subscribe to other

building lists

<https://www.fm.virginia.edu/resources/outagesubs.html>