

ALERT*ALERT*ALERT*ALERT**Health System Planned Outage Notification***Please Post Centrally in Your Department***EMERGENCY****Fire Alarm System Outage
Fire System Panel****BLDG: 1602 UVA Orthopedic Center Ivy RD.**

In order to resolve airflow issues with the SPD cart wash, several exhaust air valves need to be replaced above the ceiling in rooms G016 and G024. This will require hot work above the ceiling as well as some work in the immediate vicinity of the valves. We anticipate the hot work occurring over the first day, with the second and third day comprising testing and checkout. Due to the hot work required, we will be placing the fire alarm system on test during this period.

*****Please Review Your Local Downtime Activation Plan in Advance of This Outage*****

While no interruptions in service are expected, beyond those indicated in this notice, you should review your local area response plan prior to the outage. For unexpected issues related to this outage please report to Help Desk at 4-2267 and your local clinical leadership for operational response.

Scheduled Start Date and Time:	2022-Sep-21 07:00
Scheduled End Date and Time:	2022-Sep-23 18:00
Work Order Number:	3070890-94600
Outage Number:	
Outage Coordinator:	William (Will) Mayo 434-465-3230
POC for Group Performing Work:	Whiting Turner Jon Evers 7035814877
POC for Group Performing Work:	Whiting-Turner Matt Nordberg 804-312-4489

Customers with Whom the Outage was Coordinated:	John Marshal Senior CAM
---	-------------------------

The specified utility or utilities will be out of service as noted. Please advise the Outage Coordinator immediately if this cannot be accommodated in areas under your control or direction.

ALERT*ALERT*ALERT*ALERT

Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists

<https://www.fm.virginia.edu/resources/outagesubs.html>