

15534

**\*ALERT\*ALERT\*ALERT\*ALERT\*****Facilities Management Outage Notification***Please Post Centrally in Your Department***Chilled Water Outage****BLDG: 2085 Monroe Hill House****ALL FLOORS AFFECTED****Impact to Building Occupants: No Cooling****This Outage Will Occur Daily: -**

<b>Scheduled Start Date and Time:</b>	2023-Jul-27 09:00
<b>Scheduled End Date and Time:</b>	2023-Jul-27 15:00
<b>Reason for Outage:</b>	tie-in new chillwater piping
<b>Requested By:</b>	Clayton Roberts (UVA FM E&U)
<b>Outage Coordinator</b>	Clayton Roberts 434-270-4874
<b>Customers with Whom the Outage was Coordinated:</b>	James Coan
<b>Outage Approved By:</b>	Shawn Ragland (UVA - Facilities Management)

**Important Notes:**

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) PRIOR TO THE START and upon COMPLETION of all work

**\*ALERT\*ALERT\*ALERT\*ALERT\*****Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists**<https://www.fm.virginia.edu/resources/outagesubs.html>