

19381

ALERT*ALERT*ALERT*ALERT**Facilities Management Outage Notification***Please Post Centrally in Your Department***EMERGENCY****Water Hot and Cold Outage****BLDG: 2148 Student Health And Wellness Center****ALL FLOORS AFFECTED****Impact to Building Occupants: No Cold Water, No Hot Water, No Drinking Water, No Flushing or Shower water****Emergency Outage to stop a leak on 3rd floor, Isolation Valve did not stop the water.****No fixtures will have water supply during the duration of the outage.****Contact our team by email at the following addresses if you have any additional concerns:****Randy Spencer: DRS2Y@virginia.edu****Jacob Campbell: JRC3ZZ@virginia.edu****We apologize for the inconvenience and thank you for your understanding.**

Scheduled Start Date and Time:	2024-Jun-03 10:53
Scheduled End Date and Time:	2024-Jun-03 11:30
Reason for Outage:	Ceiling Leak on the 3rd floor on the main line, valve did not shut water off. Shutting down to prevent water loss and isolate the leak while stop is put in place.
Requested By:	Jacob Campbell (UVA Facilities Management)
Outage Coordinator	Donald (Randy) Spencer 434-531-6993
Customers with Whom the Outage was Coordinated:	Charles Walcott, Student Health and Wellness Facility Manager, 434-982-4483, CRW5Q@virginia.edu
Outage Approved By:	Randy Spencer (UVA FM Operations)

Important Notes:

1. The specified utility or building system will be out of service as noted above. Please advise the Outage Coordinator immediately if this can not be accommodated in areas under your control or direction
2. Those performing work associated with this outage **MUST** notify the Systems Control Center (982-4685) **PRIOR TO THE START** and upon **COMPLETION** of all work

ALERT*ALERT*ALERT*ALERT

Please use the below link to unsubscribe from these notification, change, or subscribe to other building lists

<https://www.fm.virginia.edu/resources/outages/outagesubs.html>